Fac # OFINP Date

DRAFT ADEM 3 YEAR OVERFILL PREVENTION EQUIPMENT INSPECTION REPORT

Questions on how to complete this form should be directed to the Groundwater Branch, UST Compliance Section at (334) 270-5655

Questions on now to complete this form should be directed to the Groundwater Branch, US1 Compliance Section at (334) 270-3655					
Facility Name: Owner:					
Address:			Address:		
City, County, Zip:			City, State, Zip:		
Facility I.D. #: Phone #:					
Inspector Name:			Inspector Phone #:		
Inspector Company:					
Instructions					
 Submit a completed copy of this form within 30 days of performing test to: Groundwater Branch, PO Box 301463 Montgomery, AL 36130-1463, or fax to: (334) 270-5631, or email to: USTcompliance@adem.alabama.gov. This form allows you to record up to 5 ADEM Unique Tank Numbers, assuming that the Facility ID Number remains the same. Complete portion of form pertaining to type of equipment inspected for each tank. Inspection must be performed in accordance with a nationally recognized code of practice (such as PEI RP-1200 or equivalent) or the manufacturer's instructions. Keep a record copy of this inspection for 3 years. 					
ADEM Unique Tank #	ļ				
Product Stored					
Was Overfill Device Removed?	□ yes	□ yes	□ yes	□ yes	□ yes
	□ no	□ no	□ no	□ no	□ no
Automatic Shutoff Device Inspection					
Drop tube and float free of debris?	□ yes	□ yes	□ yes	□ yes	□ yes
Float moves freely and poppet	□ no	□ no □ yes	□ no □ yes	□ no □ yes	□ no
moves into path of flow?	□ yes □ no	□ yes □ no	□ yes	□ yes □ □ no	□ yes □ no
·	□ yes	□ yes	□ yes	□ yes	□ yes
Bypass valve free of blockage?	□ no	□ no	□ no	□ no	□ no
(where applicable)	□ n/a	□ n/a	□ n/a	□ n/a	□ n/a
Flapper adjusted to shut off flow at	□ yes	□ yes	□ yes	□ yes	□ yes
95% capacity?	□ no	□ no	□ no	□ no	□ no
High Level Alarm Inspection					
Overfill alarm activate in test mode	□ yes	□ yes	□ yes	□ yes	□ yes
at console?	□ no	□ no	□ no	□ no	□ no
Alarm can be heard or seen from	□ yes	□ yes	□ yes	□ yes	□ yes
where the tank is filled?	□ no	□ no	□ no	□ no	□ no
All associated floats move freely?	□ yes	□ yes	□ yes	□ yes	□ yes
,	□ no	□ no	□ no	□ no	□ no
Alarm activates at 90% capacity?	□ yes □ no	□ yes □ no	□ yes □ no	□ yes □ no	□ yes □ no
Ball Float Valve Inspection					
	□ yes	□ yes	ges	□ yes	□ yes
Ball float cage free of debris?	□ no	□ no	□ no	□ no	□ no
Ball moves freely in cage and is	□ yes	□ yes	□ yes	□ yes	□ yes
free of damage?	□ no	□ no	□no	□no	□no
Vent hole in pipe is open and near	□ yes	□ yes	□ yes	□ yes	□ yes
the top of the tank?	□ no	□ no	□ no	□ no	□ no
Ball float pipe is proper length to	□ yes	□ yes	□ yes	□ yes	□ yes
activate at 90% capacity?	□ no	□ no	□ no	□ no	□ no
Tank top fittings are vapor tight	□ yes	□ yes	□ yes	□ yes	□ yes
and free of leaks?	□ no	□ no	no	no	□ no
Inspection Results for Automatic Shutoff Device or High Level Alarm or Ball Float Valve					
Results of Inspection: ("No" answer to any item indicates	□ pass	□ pass	□ pass	□ pass	☐ pass
inspection failure.)	□ fail	□ fail	☐ fail	□ fail	☐ fail
Inspector's initials and	/ /	/ /	/ /	/ /	/ /
Inspection date	, ,	1 1			/ /
Repairs Needed	Date of Repair	Description of any Repairs			